

Using Command Block to Print Screen

Settings of Command Bit and Parameters		
Operation	Command Bit #8	Parameter One Register
Print the Top Screen	1	(No parameter one register)
Print the Top Screen	1	0
Print the Specified Screen (Note)	1	Number of the screen

Note: The operation is not supported by PL035/037/057/058.

PV/PL Models

Settings of Command Bit and Parameters				
Operation	Command Bit #15	Parameter One Register	Parameter Two Register	Filename Format
Print Screen to File (in 256-color BMP format)	1	6	Number of the screen	S<ID>_<Date>_<Time>.bmp
Print Screen to File (in 64K-color BMP format)	1	7	Number of the screen	S<ID>_<Date>_<Time>.bmp

SCADA Software

Settings of Command Bit and Parameters				
Operation	Command Bit #15	Parameter One Register	Parameter Two Register	Filename Format
Print Screen to File (in BMP format; the color resolution follows the setting of the	1	6	Number of the screen	S<ID>_<Date>_<Time>.bmp

PC)				
Print Screen to File (in JPG format)	1	7	Number of the screen	S<ID>_<Date>_<Time>.jpg

Note:

<ID>: Number of the screen

<Date>: date when saving the data; format is YYMMDD

<Time>: time when saving the data; format is hhmmss