



VERIFICATION OF COMPLIANCE

This is to certify that the product listed in follows was (were) tested in the BTL EMC Laboratory to comply with the required criteria levels of the follow-mentioned Generic Standards or Product Family Standard(s) and/or Basic Standard(s) based-on the essential conformity requirements of EMC Directive 2014/30/EU.

Equipment Thermocouple Input Module
Model Name ADAM-5018, ADAM-5018XXXXXXXXXXXXXXXXXX (where "X" may be any alphanumeric character, blank or "-")
Brand Name Advantech
Applicant Advantech Co.,LTD.
Address No.7,Street 6,ShangDi Zone, Haidian District,Beijing

Standard(s) AS/NZS CISPR 32:2015 / CISPR 32:2015+C1:2016
EN 55011:2009+A1:2010 (Group 1, Class A)
EN 55032:2015+AC:2016 Class A / EN 61000-6-4:2007 +A1:2011
EN 61000-3-2:2014 Class A
EN 61000-3-3:2013
EN 55024:2010+A1:2015 / EN 61000-6-2:2005 +AC:2005

Report(s) BTL-EMC-1-1905C073D

The test data, data evaluation, and equipment configuration contained in our test report(s) above was (were) obtained utilizing the test procedures, test instruments, test sites that has been accredited according to the ISO/IEC 17025 quality assessment standard and technical standard(s). The test data contained in the referenced test report relate only to the EUT sample and item(s) tested.

Kevin Li
Authorized Signatory



BTL INC.

No.3, Jinshagang 1st Road, Shixia, Dalang Town,
Dongguan, Guangdong, China.
TEL: +86-769-8318-3000
FAX: +86-769-8319-6000

