

WebAccess AE Technical Share Document

Date	2018 / 04 / 09	SR#	
Category	☒ FAQ ☐ SOP	Related OS	Win7, Win10, Windows Server
Abstract			
Keyword	WebAccess/SCADA, Port		
Related Product	N/A		

■ Ports Used

1. HTTP: 80

Project Name	demo
Project Description	Project Description
Project Node IP Address	NB050313
Project Primary TCP Port	0
Project Timeout	0
Remote Access Code	
Project Node HTTP Port	80
Log Changes to System Log	No

2. HTTPS: 443

Redirect HTTP to HTTPS

Enable ☐ Yes ☒ No

3. RPC: 4592, 14592

Node Name	scada		
Node Description			
SCADA Node IP Address	NB050313		
Primary TCP Port	4592	Secondary TCP Port	14592
Node Timeout	0		

4. MQTT: 1883

MQTT Broker Settings

Enable ☒ Yes ☐ No

UserName

Password ☐ Show Password

TCP Port

Project Node Public IP

5. Dashboard: 8081

Dashboard Settings	
Dashboard Port	8081

6. OPC UA Server: 12346
 7. WASCADA/Modbus Server: 504
 WASCADA:

Device Name	WASCADA		
Description	Super SCADA		
Unit Number	0		
Device Type	WASCADA ▼		
Primary	IP Address	192.168.0.1	
	Port Number	504	
	Device Address	if other than Unit Number	

Modbus Server:

Port		[Cancel]	Submit
Name	ModbusServer ×		
Port Type	TCPIP ▼		
TCP Port	504		
Description	Description		
ENABLE_EXCEPTION	☐ Yes ☒ No		

8. APP: 3000
 9. Software key: 8880

■ Reference